



LISTER CO

Lister[®]

SOĞUK ODA SİSTEMLERİ

FRESCOLD POZITIF

TEKNİK VERİLER

PRESENTED BY:

ASGHAR AFSHARI

General Manager of
LİSTER

LİSTER İNC.

YÜKSELİŞ MAH.
2116 SK
ÖZEN APT KEPEZ
ANTALYA

FRESCOLD POZITIF



FRESCOLD SEMİ HERMETİK NEGATİF GRUPLAR R 404A Evaporatör Temperature -25 C, Condanser Temperature +45 C

| TİP | SOĞ.KP | HP | KOMP.GÜCÜ | S.E.K | COMP.TİPİ | V-M3 |
|-----------------|--------|-----|-----------|-------|-----------|-----------|
| RFD-Q5.28.1Y-N | 7755 | 5 | 4.60 | 1.69 | H503 CS | 81/110 |
| RFD-Q5.33.1Y-N | 9251 | 5 | 5.48 | 1.69 | H751 CS | 111/145 |
| RFD-Q7.36.1Y-N | 10442 | 7.5 | 6.09 | 1.71 | H801 CS | 146/265 |
| RFD-S8.42.Y-N | 12078 | 8 | 6.62 | 1.82 | H1001 CS | 266/370 |
| RFD-S10.52.Y-N | 15081 | 10 | 8.42 | 1.79 | H1501 CS | 371/500 |
| RFD-S15.56.Y-N | 16665 | 15 | 9.04 | 1.84 | H1601 CS | 501/600 |
| RFD-S20.84.Y-N | 23310 | 20 | 13.38 | 1.74 | H2500 CS | 601/850 |
| RFD-V25.93.Y-N | 24807 | 25 | 14.27 | 1.74 | H2700 CS | 851/1000 |
| RFD-Z25.106.Y-N | 29672 | 25 | 17.35 | 1.71 | H3000 CS | 1001/1200 |
| RFD-Z30.126.Y-N | 34477 | 30 | 19.25 | 1.79 | H3000 CS | 1201/1350 |

YÜKSELİŞ MAH. 2116 SK ÖZMEZ APT KEPEZ / ANTALYA

PRESENTED BY:

ASGHAR AFSHARI

General Manager of

LİSTER

FRESCOLD POZITIF